


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm		
NAME: 5RS150	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 85.84 lm/W			
MODEL	2700K	Imax(cd)	557.6	S/MH(C0/180)	0.96
NOMINAL POWER(W)	6	LOR(%)	100.0	S/MH(C90/270)	0.89
RATED VOLTAGE(V)	230	TOTAL FLUX(lm)	526.82	h UP,DN(C0-180)	0.1,48.9
NOMINAL FLUX(lm)	526.822	CIE CLASS	DIRECT	h UP,DN(C180-360)	0.1,50.9
LAMPS INSIDE	1	h up(%)	0.2	CIBSE SHR NOM	0.75
TEST VOLTAGE(V)	231.2	h down(%)	99.8	CIBSE SHR MAX	0.95

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3DEG
 Operators: DAMIN
 Test Date: 2019-12-02

g Range: 0 - 180DEG
 Interval: 1.0DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.416
 Humidity: 65.0%
 Test Distance: 9.140m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


g	C0	C45	C90	C135	C180	C225	C270	C315	g	F zone	F total	%lum,lamp
10	520.3	521.5	531.7	538.7	542.0	538.5	529.6	523.1	0- 10	51.73	51.73	9.82,9.82
20	404.3	397.9	433.3	460.0	461.4	456.3	432.5	408.1	10- 20	137.1	188.8	35.8,35.8
30	233.6	227.2	275.4	310.0	311.8	309.8	269.7	231.5	20- 30	161.7	350.5	66.5,66.5
40	70.70	68.69	96.82	125.5	135.3	134.6	99.08	73.64	30- 40	111.9	462.4	87.8,87.8
50	15.06	14.05	21.08	28.18	32.99	34.91	25.60	16.54	40- 50	41.39	503.8	95.6,95.6
60	7.029	6.874	7.858	8.816	9.512	9.699	8.406	7.182	50- 60	11.84	515.6	97.9,97.9
70	3.617	3.549	4.139	4.973	5.407	5.488	4.480	3.824	60- 70	6.131	521.8	99,99
80	1.214	1.071	1.651	2.174	2.326	2.246	1.589	1.202	70- 80	3.160	524.9	99.6,99.6
90	0	0	0.0132	0.0730	0.0380	0.0512	0	0	80- 90	0.7172	525.6	99.8,99.8
100	0	0	0	0	0	0	0	0	90-100	0.0017	525.6	99.8,99.8
110	0	0	0	0	0	0	0	0.0065	100-110	0.0004	525.6	99.8,99.8
120	0.0192	0.0194	0	0	0.0322	0.0260	0.0456	0.0524	110-120	0.0098	525.7	99.8,99.8
130	0.1539	0.1744	0.0977	0.0850	0.1218	0.1166	0.1500	0.1768	120-130	0.0667	525.7	99.8,99.8
140	0.3525	0.3560	0.2998	0.2550	0.2887	0.2851	0.3390	0.3732	130-140	0.1684	525.9	99.8,99.8
150	0.5897	0.5957	0.5212	0.4970	0.5194	0.5117	0.5672	0.5889	140-150	0.2697	526.2	99.9,99.9
160	0.8206	0.8224	0.7690	0.7261	0.7569	0.7580	0.8020	0.8443	150-160	0.3069	526.5	99.9,99.9
170	1.013	1.010	0.9969	0.9420	0.9939	0.9909	1.023	1.047	160-170	0.2528	526.7	100,100
180	1.122	1.120	1.115	1.112	1.122	1.120	1.121	1.119	170-180	0.1006	526.8	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:DAMIN
 Test Date:2019-12-02

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.416
 Humidity:65.0%
 Test Distance:9.140m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm		
NAME: 5RS150	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-12-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.416
Humidity:65.0%
Test Distance:9.140m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm		
NAME: 5RS150	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:

r _{cc}	80%			70%			50%			30%			10%			0
r _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



WEC AND CCEC

Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm		
NAME: 5RS150	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Wall Exitance Coefficients(WEC)															
0.0																
1.0	.188	.107	.034	.182	.104	.033	.169	.097	.031	.157	.091	.029	.146	.085	.027	
2.0	.181	.099	.030	.175	.096	.030	.164	.091	.028	.154	.086	.027	.145	.082	.026	
3.0	.172	.092	.027	.167	.089	.027	.158	.085	.026	.149	.082	.025	.141	.078	.024	
4.0	.163	.085	.025	.159	.083	.025	.151	.080	.024	.144	.077	.023	.137	.074	.023	
5.0	.155	.079	.023	.152	.078	.023	.145	.075	.022	.138	.073	.022	.132	.071	.021	
6.0	.148	.074	.021	.145	.073	.021	.139	.071	.021	.133	.069	.020	.127	.067	.020	
7.0	.141	.070	.020	.138	.069	.020	.133	.067	.019	.128	.065	.019	.123	.064	.019	
8.0	.135	.066	.019	.132	.065	.018	.127	.064	.018	.123	.062	.018	.118	.061	.018	
9.0	.129	.062	.017	.127	.062	.017	.122	.060	.017	.118	.059	.017	.114	.058	.017	
10.0	.123	.059	.016	.121	.059	.016	.117	.057	.016	.114	.056	.016	.110	.055	.016	

rcc	80%			70%			50%			30%			10%			0
rw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
rfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Ceiling Cavity Exitance Coefficients(CCEC)															
0.0	.192	.192	.192	.164	.164	.164	.112	.112	.112	.064	.064	.064	.021	.021	.021	
1.0	.174	.159	.146	.149	.136	.125	.102	.094	.087	.058	.054	.050	.019	.017	.016	
2.0	.159	.134	.113	.136	.115	.098	.093	.080	.068	.054	.046	.040	.017	.015	.013	
3.0	.147	.115	.090	.126	.100	.078	.087	.069	.055	.050	.040	.032	.016	.013	.011	
4.0	.137	.101	.073	.118	.087	.063	.081	.061	.045	.047	.036	.026	.015	.012	.009	
5.0	.129	.089	.060	.111	.077	.052	.076	.054	.037	.044	.032	.022	.014	.010	.007	
6.0	.122	.080	.050	.105	.069	.044	.072	.049	.031	.042	.029	.018	.014	.009	.006	
7.0	.115	.073	.043	.099	.063	.037	.069	.044	.026	.040	.026	.016	.013	.009	.005	
8.0	.110	.067	.037	.094	.058	.032	.065	.041	.023	.038	.024	.014	.012	.008	.005	
9.0	.105	.061	.032	.090	.053	.028	.062	.037	.020	.036	.022	.012	.012	.007	.004	
10.0	.100	.057	.029	.086	.050	.025	.060	.035	.018	.035	.021	.011	.011	.007	.004	

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-12-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.416
Humidity:65.0%
Test Distance:9.140m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm											
NAME: 5RS150					TYPE:			WEIGHT:			
SPEC.:					DIM.:			SERIAL No.:			
MFR.:					SUR.:			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions	Viewed crosswise					Viewed endwise					
x = 2H y = 2H	22.6	23.6	22.8	23.7	23.9	23.5	24.5	23.7	24.7	24.9	
	3H	22.6	23.5	22.8	23.7	23.9	23.5	24.4	23.8	24.6	24.8
	4H	22.6	23.4	22.9	23.7	23.9	23.5	24.4	23.8	24.6	24.8
	6H	22.5	23.4	22.9	23.6	23.9	23.5	24.3	23.8	24.5	24.8
	8H	22.5	23.3	22.8	23.6	23.8	23.5	24.2	23.8	24.5	24.8
	12H	22.5	23.2	22.8	23.5	23.8	23.4	24.2	23.7	24.4	24.7
4H	2H	22.4	23.3	22.7	23.5	23.7	23.3	24.2	23.6	24.4	24.6
	3H	22.5	23.2	22.8	23.5	23.8	23.4	24.1	23.7	24.4	24.7
	4H	22.5	23.2	22.9	23.5	23.8	23.4	24.1	23.8	24.4	24.7
	6H	22.5	23.1	22.9	23.5	23.8	23.4	24.0	23.8	24.4	24.7
	8H	22.5	23.0	22.9	23.4	23.8	23.4	24.0	23.8	24.3	24.7
	12H	22.5	23.0	22.9	23.3	23.7	23.4	23.9	23.8	24.3	24.7
8H	4H	22.4	23.0	22.8	23.4	23.7	23.3	23.9	23.7	24.2	24.6
	6H	22.5	22.9	22.9	23.3	23.7	23.4	23.8	23.8	24.2	24.6
	8H	22.4	22.8	22.9	23.3	23.7	23.3	23.7	23.8	24.2	24.6
	12H	22.4	22.7	22.9	23.2	23.7	23.3	23.7	23.8	24.1	24.6
12H	4H	22.4	22.9	22.8	23.3	23.7	23.3	23.8	23.7	24.2	24.5
	6H	22.4	22.8	22.9	23.3	23.7	23.3	23.7	23.8	24.1	24.6
	8H	22.4	22.7	22.9	23.2	23.7	23.3	23.6	23.8	24.1	24.6
Variations with the observer position at spacings:											
S = 1.0H	+ 2.7 / - 4.2					+ 3.3 / - 4.6					
1.5H	+ 4.6 / - 3.9					+ 5.2 / - 4.6					
2.0H	+ 4.0 / - 1.5					+ 5.2 / - 2.0					

CIE Pub.117, 526.8 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -2.2)
Area: 0.001256 m2

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-12-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
g Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.416
Humidity:65.0%
Test Distance:9.140m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm		
NAME: 5RS150	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	84	77	73	83	77	73	83	76	73	69
0.80	92	85	81	91	85	81	90	84	81	77
1.00	97	91	87	96	90	86	94	90	86	82
1.25	101	96	92	100	95	91	98	94	91	86
1.50	104	99	95	103	98	95	101	97	94	89
2.00	107	103	99	106	102	99	103	100	97	92
2.50	109	105	102	108	104	101	104	101	99	93
3.00	111	107	104	109	106	103	106	103	101	94
4.00	113	110	108	111	108	106	107	105	103	96
5.00	114	112	110	112	110	108	108	107	105	97
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:DAMIN
 Test Date:2019-12-02

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.416
 Humidity:65.0%
 Test Distance:9.140m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm		
NAME: 5RS150	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:DAMIN
 Test Date:2019-12-02

g Range: 0 - 180DEG
 Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.416
 Humidity:65.0%
 Test Distance:9.140m [K=1.0000]
 Remarks:

AAI Figure

Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm		
NAME: 5RS150	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:

Flux out:350.5 lm




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3DEG
 Operators: DAMIN
 Test Date: 2019-12-02

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.416
 Humidity: 65.0%
 Test Distance: 9.140m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM

Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm		
NAME: 5RS150	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3DEG
 Operators: DAMIN
 Test Date: 2019-12-02

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.416
 Humidity: 65.0%
 Test Distance: 9.140m [K=1.0000]
 Remarks:

LED Avg.L Report

Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm		
NAME: 5RS150	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	11798
L_0~180(75)av	9278
L_0~180(85)av	5830
L_90~270(65)av	11557
L_90~270(75)av	8871
L_90~270(85)av	4410
L_45(65)av	11606
L_45(75)av	9188
L_45(85)av	5031

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-12-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.416
Humidity:65.0%
Test Distance:9.140m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: DAMIN
Test Date: 2019-12-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.416
Humidity: 65.0%
Test Distance: 9.140m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:230.51V I:0.0295A P:6.1374W PF:0.9028 Freq:49.99Hz Lamp Flux:526.822x1 lm																	
NAME: 5RS150									TYPE:						WEIGHT:		
SPEC.:									DIM.:						SERIAL No.:		
MFR.:									SUR.:						Shielding Angle:		

Table--1

UNIT: cd

C(°) g (°)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5			
0	554	554	554	554	554	554	554	554	554	554	554	554	554	554	554	554			
5	542	541	542	544	546	549	551	554	555	554	553	550	547	545	543	541			
10	520	519	521	527	532	535	539	543	542	540	538	533	530	526	523	520			
15	474	472	470	483	496	506	510	517	516	513	510	502	495	485	478	470			
20	404	400	398	414	433	452	460	466	461	459	456	442	432	418	408	397			
25	326	319	320	332	360	379	388	395	388	390	387	370	356	340	323	315			
30	234	229	227	244	275	301	310	318	312	317	310	291	270	249	231	223			
35	139	135	135	151	178	205	218	229	225	231	223	199	176	152	140	134			
40	70.7	69.4	68.7	80.2	96.8	116	125	137	135	140	135	116	99.1	81.9	73.6	69.6			
45	33.3	31.7	31.4	38.1	47.5	57.3	63.1	70.1	70.4	73.3	70.8	60.6	51.9	41.2	35.8	33.4			
50	15.1	14.4	14.0	16.6	21.1	26.2	28.2	32.6	33.0	35.1	34.9	29.8	25.6	19.7	16.5	15.2			
55	9.00	9.05	8.91	9.57	11.0	12.2	13.2	14.7	15.3	16.9	16.7	14.4	12.6	10.2	9.52	8.99			
60	7.03	6.93	6.87	7.18	7.86	8.43	8.82	9.15	9.51	9.75	9.70	8.93	8.41	7.55	7.18	6.90			
65	5.26	5.13	5.13	5.40	5.90	6.34	6.76	7.11	7.26	7.40	7.27	6.78	6.37	5.87	5.49	5.25			
70	3.62	3.52	3.55	3.77	4.14	4.63	4.97	5.35	5.41	5.54	5.49	4.98	4.48	4.10	3.82	3.64			
75	2.37	2.22	2.27	2.48	2.84	3.24	3.46	3.63	3.67	3.78	3.72	3.35	2.93	2.65	2.50	2.37			
80	1.21	1.09	1.07	1.29	1.65	1.94	2.17	2.31	2.33	2.36	2.25	1.94	1.59	1.31	1.20	1.17			
85	0.19	0.11	0.14	0.18	0.42	0.70	0.96	1.13	1.08	1.06	0.91	0.74	0.55	0.29	0.20	0.17			
90	0.00	0.00	0.00	0.00	0.01	0.00	0.07	0.07	0.04	0.12	0.05	0.00	0.00	0.00	0.00	0.00			
95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
105	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
110	0.00	0.01	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00			
115	0.00	0.04	0.00	0.03	0.00	0.01	0.00	0.01	0.01	0.00	0.01	0.00	0.03	0.00	0.02	0.00			
120	0.02	0.06	0.02	0.06	0.00	0.03	0.00	0.03	0.03	0.00	0.03	0.00	0.05	0.03	0.05	0.01			
125	0.07	0.13	0.06	0.10	0.09	0.07	0.02	0.05	0.06	0.03	0.06	0.03	0.08	0.09	0.11	0.08			
130	0.15	0.20	0.17	0.17	0.10	0.14	0.08	0.12	0.12	0.08	0.12	0.08	0.15	0.13	0.18	0.19			
135	0.24	0.28	0.25	0.26	0.19	0.22	0.17	0.19	0.20	0.16	0.19	0.18	0.24	0.21	0.27	0.26			
140	0.35	0.39	0.36	0.37	0.30	0.31	0.26	0.29	0.29	0.25	0.29	0.28	0.34	0.32	0.37	0.37			
145	0.49	0.51	0.51	0.49	0.40	0.42	0.37	0.39	0.40	0.37	0.39	0.40	0.45	0.44	0.50	0.48			
150	0.59	0.64	0.60	0.60	0.52	0.55	0.50	0.51	0.52	0.48	0.51	0.49	0.57	0.55	0.59	0.62			
155	0.69	0.75	0.71	0.72	0.65	0.67	0.61	0.64	0.64	0.59	0.63	0.62	0.69	0.69	0.73	0.71			
160	0.82	0.88	0.82	0.85	0.77	0.78	0.73	0.76	0.76	0.70	0.76	0.74	0.80	0.79	0.84	0.81			
165	0.92	0.97	0.92	0.96	0.90	0.90	0.84	0.89	0.88	0.82	0.87	0.85	0.93	0.90	0.96	0.92			
170	1.01	1.06	1.01	1.04	1.00	1.01	0.94	1.00	0.99	0.95	0.99	0.96	1.02	1.02	1.05	1.02			
175	1.10	1.11	1.11	1.10	1.05	1.08	1.03	1.08	1.08	1.03	1.08	1.04	1.08	1.06	1.10	1.07			
180	1.12	1.13	1.12	1.12	1.11	1.12	1.11	1.11	1.12	1.11	1.12	1.12	1.12	1.12	1.12	1.12			

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-12-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.416
Humidity:65.0%
Test Distance:9.140m [K=1.0000]
Remarks: